

		4			
		GCS-11			
		800			
消防泵	喷淋泵	地下室照明	5F 空调电源箱	传达室	
76.4	39.2	3.9	144	以现场为准	
1(TM200D)			1(TM250D)		
	1(TM100D)	1(TM16D)		以现场为准	
1(300/5)	1(100/5)	1(50/5)	1(250/5)	以现场为准	
-1DX11 备用电	-1DX10 备用电	-1MX1	5AC-MU1		
NH-VV 3x95+2x50 CT	NH-VV 3x35+2x16 CT	BV-500 5x4 G32	WDZ-YJY 4x150+1x70 CT	以现场为准	
			新增		

低压配电系统图（一）

配电柜编号		16	17	18		
配电柜型号		GCS-01	GCS-06	GCS-11		
配电柜宽度 (mm)		800	800	800		
用 途		总 柜	热水机组(冬季)	暖水泵(冬)	十三层空调用	辅助电加热器
回路容量 (KW)		540	482	20.18	103.5	40
主要电 器元 件	断路器	M10-1000/N1/4				
	断路器	C1001/4 STR25DE				
	断路器	NS400H/4				
	断路器	NS250H/4			1(TM250D)	
	断路器	NS160H/4				1(TM160D)
	断路器	NS100H/4		1(TM63D)		1(TM80D)
	电流互感器	SDL				
电流互感器		SDH	3(1000/5)	3(1000/5)	1(100/5)	1(250/5)
回路编号			5F 空调电源箱	-1DX1	14DX3	9DX1
主 备用电			5AC-MU2			-1DX3
配出管线		1js=861A	4xWDZ-YJY-4x150 +1x70 CT	YJV-1KV 5x10 G50	YJV-1KV 3x70+2x35 CT	YJV-1KV 5x16 CT/TC40
			新增			3x35+2x16 G80

阴影部分为利旧

低压配电系统图（三）

平面区位	Key plan	备注	Notes	合作设计			Codesign						建设单位	Client			图纸内容	Dwg title
														南通市公安局				
														工程名称				
														南通市公安局部分用房整改				
														Project title				
														子项名称				
														Item title				